



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(274/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

15 April 2021

Sing Lee Metal Trading Co Ltd  
Flat 3A, Yip Kwong Ind. Bldg.,  
39-41 Beech Street, Tai Kok Tsui,  
Kowloon, Hong Kong

(Attn.: Mr Myron HO)

Dear Sir,

**Approval of "PO SING" Galvanized Steel Pipes  
(General Acceptance No. C20210383FS)**

Your letters dated 3 February 2021 and 8 March 2021 refer.

Having considered the test report ref. PMA10514 issued on 1 February 2021 by ETS-Testconsult Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.


**Name of Manufacturer:** Po Sing Steel Pipe

**Country of Origin:** the Mainland of China

**Brand:** Po Sing

**Details of Pipes:** Galvanized steel pipes (class medium)

**Size:** 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

**Body Markings:**  Po Sing BS1387 / BSEN10255  
Series (MEDIUM) W size x length

**Expiry Date:** 28 January 2026



**Proviso:** The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only